



CLEAN 10 TECHNICAL INFORMATION

DIRECTIONS :

Add 1 to 2 bottles (5 to 10 Litres or 1.3 to 2.6 gallons) of AXI-THERM CLEAN 10 for every 100 Litres (25 gallons) of water (Dosage: 5 – 10 %). It must circulate for 3 to 30 days when using the existing system circulator. The boiler may be on or off. Once the cleaning operation is finished, the system should be well drained and rinsed. Rinsing should continue until the water runs clear. Refill the system with demineralized water provided by an Axiom PUROPAL demineralizer. Add AXI-THERM PROTECT 1 for complete system protection against corrosion, limescale and sludge formation.

ENVIRONMENTAL AND SAFETY INFORMATION :

For professional use only.

Before adding to the system, ensure that the system water does not contain other chemicals. Lower concentrations do not yield satisfactory results. Higher concentrations have no adverse effects.

Do not use in potable water systems. Do not ingest. Do not dispose of waste through the environment. Keep out of reach of children. The product is not classified according to the Globally Harmonized System (GHS).

SKU	Purpose	Bottle Size	Treatment Volume	Case Qty
AXTH-C10-5L	System & Boiler Cleaner	5L (1.32 gal)	50 to 100 litres (12.5 to 25 gal)	4
AXTH-C10-20L	System & Boiler Cleaner	20L (5.28 gal)	200 to 400 litres (50 to 100 gal)	1

ACCESSORIES :

- AXTH- Water Test** -- Axi-Therm Boiler Water Quality Titration Test Kit
- PruoPal-1** -- Disposable Demineralizer Cartridge

Project _____
 Consultant _____
 Unit Tag _____

Location _____
 Contractor _____
 Sales Agent _____