

Axi-Therm Chemical



CLEAN 3

(Commissioning Cleaner)

- A Provides energy savings by removing oil residue and metal oxides from **new** installations
- A Easy to use, the cleaner can be circulated with the boiler on or off
- A Reduces maintenance costs
- A Neutral pH does not corrode or damage gaskets, plastics, or metals (steel, copper, and aluminum)
- A Eco friendly chemicals do not contain harmful or hazardous substances
- A Low concentration requirements
- A Available in 500 mL (16.9 oz.) ,2 litre (½ U.S. gallon) bottles, and 20L (5 U.S. Gallon) jugs

Dosage: 0.5%

Suitable for all kinds of new hydronic heating and cooling systems: traditional hydronic heating systems, chilled water systems, and geothermal systems. Provides energy savings by removing oil residue and metal oxides from newly installed hydronic systems. Safe for use with all metals (steel, copper, and aluminum).

✉ info@axiomind.com

☎ (877)651-1815

🌐 WWW.AXIOMIND.COM

AXI-THERM



CLEAN 3 TECHNICAL INFORMATION

DIRECTIONS :

Add 1 bottle (500 mL or 16.9 oz.) of AXI-THERM CLEAN 3 for every 100 litres (25 gallons) of water (Dosage: 0.5 %). It must circulate for at least 2 days when using the existing system circulator. The product may remain in the system for up to 30 days and the boiler may be on or off during the cleaning period. Flushing the system with the a (Flush cart) can reduce the cleaning operation to 2 to 4 hours. Once the cleaning operation is completed, the system should be well drained and rinsed. Rinsing should continue until the water runs clear. If the water does not run clean, repeat the cleaning session. Refill the system with demineralized water provided by an Axiom PUROPAL demineralizer. Add AXI-THERM PROTECT 1 for complete system protection.

ENVIRONMENTAL AND SAFETY INFORMATION :

For professional use only.

Before adding to the system, ensure that the system water does not contain other chemicals. Lower concentrations do not yield satisfactory results. Higher concentrations have no adverse effects.

Do not use in potable water systems. Do not ingest. Do not dispose of waste through the environment. Keep out of reach of children. The product is not classified according to the Globally Harmonized System (GHS).

SKU	Purpose	Bottle Size	Treatment Volume	Case Qty
AXTH-C3-500mL	Chemical Cleaner for NEW Hydronic Systems	500mL (16.9oz)	100 litres (25 gal)	12
AXTH-C3-2L	Chemical Cleaner for NEW Hydronic Systems	2L (67.6 oz.)	400 litres (100 gal)	6
AXTH-C3-20L	Chemical Cleaner for NEW Hydronic Systems	20L (5.28 gal)	4000 litres (1060 gal)	1

ACCESSORIES :

- AXTH- Water Test** -- Axi-Therm Boiler Water Quality Titration Test Kit
- PruoPal-1** -- Disposable Demineralizer Cartridge

Project _____
 Consultant _____
 Unit Tag _____

Location _____
 Contractor _____
 Sales Agent _____